

 **National Testing
Laboratories, Ltd.**


Quality Water Analysis

**Corporate Headquarters
6571 Wilson Mills Road
Cleveland, Ohio 44143**

Phone: 800-458-3330



This report package contains 25 pages.

This package contains reports from the following laboratories:

- National Testing Laboratories, Ltd. (6 pages)
- Broward Testing Laboratory, Ltd. (4 pages)
- Pace Analytical Services, Inc.- Minneapolis, MN (7 pages)
- Pace Analytical Services, Inc.- Greensburg, PA (1 page)
- EMSL Analytical Inc. (1 page)
- Radon Diagnostic Laboratory (1 page)
- Underwriters Laboratories Inc. (4 pages)

If you have any questions, please contact Susan Henderson at 1-800-458-3330.



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 1 OF 6 SAMPLE CODE: 714995

Date: 03/19/10 Report #: 714995 Laboratory ID #: MI859

Client: VALLEY CREST FARM
ATTN: PETER LECOMPTE
14 ALLERTON RD.
LEBANON, NJ 08833-

Date Collected: 01/12/10
Time Collected: 15:30
SOURCE: VALLEY CREST FARM
BOREHOLE 1
SOURCE WATER
TEMP=51

Date received at lab: 01/13/10
Collected by : E.WILSON

Time received at lab: 09:35

The results herein conform to NELAC standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request.



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 2 OF 6 SAMPLE CODE: 714995

NOTE: "*" The MCL (Maximum Contaminant Level) or an established guideline has been exceeded for this contaminant.
"ND" This contaminant was not detected at or above our lower reporting limit (LRL).
"NA" Not Analyzed.

pH analysis by EPA Method 150.1 has a 15 minute hold time from sampling to analysis. Analysis of pH past the 15 minute hold time should be considered an estimate.

Fed Id #	Analysis Performed	Method	MCL (mg/l)	LRL	Level Detected	Anal Date

Inorganic chemicals - metals:						

1002	Aluminum	200.7	0.2**	0.05	ND	01/18/10
1074	Antimony	200.8	0.006	0.003	ND	01/18/10
1005	Arsenic	200.8	0.010	0.002	ND	01/18/10
1010	Barium	200.8	2	0.10	ND	01/18/10
1075	Beryllium	200.8	0.004	0.001	ND	01/18/10
1079	Boron	200.7	---	0.10	ND	01/18/10
1015	Cadmium	200.8	0.005	0.001	ND	01/18/10
1016	Calcium	200.7	---	2.0	43	01/18/10
1020	Chromium	200.8	0.1	0.007	ND	01/18/10
1022	Copper	200.8	1.3**	0.002	ND	01/18/10
1028	Iron	200.7	0.3**	0.020	0.044	01/18/10
1030	Lead	200.8	0.015	0.001	ND	01/18/10
1031	Magnesium	200.7	---	0.10	23	01/18/10
1032	Manganese	200.8	0.05**	0.004	ND	01/18/10
1035	Mercury	200.8	0.002	0.0002	NA	
1036	Nickel	200.8	---	0.005	ND	01/18/10
1042	Potassium	200.7	---	1.0	1.4	01/18/10
1045	Selenium	200.8	0.05	0.002	ND	01/18/10
1050	Silver	200.8	0.1**	0.002	ND	01/18/10
1052	Sodium	200.7	---	1	12	01/18/10
1085	Thallium	200.8	0.002	0.001	ND	01/18/10
1095	Zinc	200.8	5**	0.004	0.032	01/18/10



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 3 OF 6 SAMPLE CODE: 714995

Fed Id #	Analysis Performed	Method	MCL (mg/l)	LRL	Level Detected	Anal Date

Inorganic chemicals - other, and physical factors:						

1927	Alkalinity (Total as CaCO3)	2320B	---	20	160	01/21/10
1004	Bromide	300.1	---	0.005	0.019	01/14/10
1017	Chloride	300.0	250**	1	25	01/13/10
1910	Corrosivity	Langelier In	---	---	-1.1	02/02/10
1025	Fluoride	300.0	4	0.10	0.12	01/13/10
1055	Sulfate	300.0	250**	5	15	01/13/10
1915	Hardness (as CaCO3)	2340C	---	10	190	01/21/10
1930	Total Dissolved Solids	2540C	500**	5	240	01/15/10
1928	Bicarbonate (as CaCO3)	2320B	---	20	160	01/21/10
1929	Carbonate (as CaCO3)	2320B	---	20	ND	01/21/10
1021	Hydroxide (as CaCO3)	2320B	---	20	ND	01/21/10
1064	Spec Cond (umhos/cm at 25C)	2510B	---	1	410	01/21/10

Fed Id #	Analysis Performed	Method	MCL (mg/l)	LRL	Level Detected	Anal Date	Anal Time

1040	Nitrate as N	300.0	10	0.05	3.6	01/13/10	15:39
1041	Nitrite as N	300.0	1	0.05	ND	01/13/10	15:39
1044	Ortho Phosphate	300.0	---	2.0	ND	01/13/10	15:39
1925	pH (Standard Units)	150.1	6.5-8.5**	---	6.5	01/13/10	13:10
4254	pH Temperature (C)				16		
0100	Turbidity (NTU)	2130B	1.0	0.1	0.2	01/13/10	13:40
1905	Color (Apparent)	2120B	15**	3.0	ND	01/13/10	14:00
2905	Foaming Agents	5540C	0.5**	0.1	ND	01/13/10	12:20
1920	Odor Threshold	2150B	3 ton**	---	ND	01/13/10	13:30

** Denotes Secondary Maximum Contaminant Level (SMCL)



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 4 OF 6 SAMPLE CODE: 714995

Fed Analysis Performed Id #	Method	MCL (mg/l)	LRL	Level Detected	Anal Date

Organic chemicals - trihalomethanes:					

2942 Bromoform	524.2	---	0.0005	ND	01/13/10
2943 Bromodichloromethane	524.2	---	0.0005	ND	01/13/10
2941 Chloroform	524.2	---	0.0005	ND	01/13/10
2944 Dibromochloromethane	524.2	---	0.0005	ND	01/13/10
2950 Total THMs	524.2	0.080	0.0005	ND	01/13/10

Organic Chemicals-Volatiles:

2990 Benzene	524.2	0.005	0.0005	ND	01/13/10
2993 Bromobenzene	524.2	---	0.0005	ND	01/13/10
2430 Bromochloromethane	524.2	---	0.0005	ND	01/13/10
2214 Bromomethane	524.2	---	0.0005	ND	01/13/10
2422 n-Butylbenzene	524.2	---	0.0005	ND	01/13/10
2428 sec-Butylbenzene	524.2	---	0.0005	ND	01/13/10
2426 tert-Butylbenzene	524.2	---	0.0005	ND	01/13/10
2982 Carbon Tetrachloride	524.2	0.005	0.0005	ND	01/13/10
2989 Chlorobenzene	524.2	0.1	0.0005	ND	01/13/10
2216 Chloroethane	524.2	---	0.0005	ND	01/13/10
2210 Chloromethane	524.2	---	0.0005	ND	01/13/10
2965 2-Chlorotoluene	524.2	---	0.0005	ND	01/13/10
2966 4-Chlorotoluene	524.2	---	0.0005	ND	01/13/10
2408 Dibromomethane	524.2	---	0.0005	ND	01/13/10
2968 1,2-Dichlorobenzene	524.2	0.6	0.0005	ND	01/13/10
2967 1,3-Dichlorobenzene	524.2	---	0.0005	ND	01/13/10
2969 1,4-Dichlorobenzene	524.2	0.075	0.0005	ND	01/13/10
2212 Dichlorodifluoromethane	524.2	---	0.0005	ND	01/13/10
2978 1,1-Dichloroethane	524.2	---	0.0005	ND	01/13/10
2980 1,2-Dichloroethane	524.2	0.005	0.0005	ND	01/13/10
2977 1,1-Dichloroethene	524.2	0.007	0.0005	ND	01/13/10
2380 cis-1,2-Dichloroethene	524.2	0.07	0.0005	ND	01/13/10
2979 trans-1,2-Dichloroethene	524.2	0.1	0.0005	ND	01/13/10
2983 1,2-Dichloropropane	524.2	0.005	0.0005	ND	01/13/10
2412 1,3-Dichloropropane	524.2	---	0.0005	ND	01/13/10
2416 2,2-Dichloropropane	524.2	---	0.0005	ND	01/13/10
2410 1,1-Dichloropropene	524.2	---	0.0005	ND	01/13/10
2228 cis-1,3-Dichloropropene	524.2	---	0.0005	ND	01/13/10
2224 trans-1,3-Dichloropropene	524.2	---	0.0005	ND	01/13/10
2992 Ethylbenzene	524.2	0.7	0.0005	ND	01/13/10



ANALYTICAL REPORT

PAGE 5 OF 6 SAMPLE CODE: 714995

Fed Id #	Analysis Performed	Method	MCL (mg/l)	LRL	Level Detected	Anal Date

Organic chemicals - volatiles						

2246	Hexachlorobutadiene	524.2	---	0.0005	ND	01/13/10
2994	Isopropylbenzene	524.2	---	0.0005	ND	01/13/10
2030	4-Isopropyltoluene	524.2	---	0.0005	ND	01/13/10
2964	Dichloromethane	524.2	0.005	0.0005	ND	01/13/10
2248	Naphthalene	524.2	---	0.0005	ND	01/13/10
2998	Propylbenzene	524.2	---	0.0005	ND	01/13/10
2996	Styrene	524.2	0.1	0.0005	ND	01/13/10
2986	1,1,1,2-Tetrachloroethane	524.2	---	0.0005	ND	01/13/10
2988	1,1,2,2-Tetrachloroethane	524.2	---	0.0005	ND	01/13/10
2987	Tetrachloroethene	524.2	0.005	0.0005	ND	01/13/10
2991	Toluene	524.2	1	0.0005	ND	01/13/10
2420	1,2,3-Trichlorobenzene	524.2	---	0.0005	ND	01/13/10
2378	1,2,4-Trichlorobenzene	524.2	0.07	0.0005	ND	01/13/10
2981	1,1,1-Trichloroethane	524.2	0.2	0.0005	ND	01/13/10
2985	1,1,2-Trichloroethane	524.2	0.005	0.0005	ND	01/13/10
2984	Trichloroethene (TCE)	524.2	0.005	0.0005	ND	01/13/10
2218	Trichlorofluoromethane	524.2	---	0.0005	ND	01/13/10
2904	Trichlorotrifluoroethane	524.2	---	0.0005	ND	01/13/10
2414	1,2,3-Trichloropropane	524.2	---	0.0005	ND	01/13/10
2418	1,2,4-Trimethylbenzene	524.2	---	0.0005	ND	01/13/10
2424	1,3,5-Trimethylbenzene	524.2	---	0.0005	ND	01/13/10
2976	Vinyl Chloride	524.2	0.002	0.0005	ND	01/13/10
2251	Methyl-Tert-Butyl-Ether	524.2	---	0.0005	ND	01/13/10
2247	Methyl Ethyl Ketone	524.2	---	0.005	ND	01/13/10
2997	o-Xylene	524.2	---	0.0005	ND	01/13/10
2995	m-Xylene (1)	524.2	---	0.0005	ND	01/13/10
2962	p-Xylene (1)	524.2	---	0.0005	ND	01/13/10
2955	Xylenes (Total)	524.2	10			



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166

(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 6 OF 6 SAMPLE CODE: 714995

Fed Id #	Analysis Performed	Method	MCL (mg/l)	LRL	Level Detected	Anal Date
2005	Endrin	505	0.002	0.00001	ND	01/20/10
2010	Lindane	505	0.0002	0.00002	ND	01/20/10
2015	Methoxychlor	505	0.04	0.0001	ND	01/20/10
2383	Total PCBs (2)	505	0.0005	0.0005	ND	01/20/10
2020	Toxaphene	505	0.003	0.001	ND	01/20/10
2110	Silvex(2,4,5-TP)	515.2	0.05	0.0002	ND	02/03/10
2105	2,4-D	515.2	0.07	0.0001	ND	02/03/10
2051	Alachlor	508.1	0.002	0.0002	NA	
2356	Aldrin	505	---	0.00007	ND	01/20/10
2050	Atrazine	508.1	0.003	0.0001	NA	
2959	Chlordane	505	0.002	0.0001	ND	01/20/10
2031	Dalapon	515.3	0.2	0.001	NA	
2440	Dicamba	515.2	---	0.001	ND	02/03/10
2933	Dichloran	505	---	0.001	ND	01/20/10
2070	Dieldrin	505	---	0.00002	ND	01/20/10
2041	Dinoseb	515.2	0.007	0.0002	ND	02/03/10
2065	Heptachlor	505	0.0004	0.00001	ND	01/20/10
2067	Heptachlor Epoxide	505	0.0002	0.00001	ND	01/20/10
2274	Hexachlorobenzene	505	0.001	0.0001	ND	01/20/10
2042	Hexachlorocyclopentadiene	505	0.05	0.0001	ND	01/20/10
2934	Pentachloronitrobenzene	505	---	0.0001	ND	01/20/10
2326	Pentachlorophenol	515.2	0.001	0.00004	ND	02/03/10
2040	Picloram	515.2	0.5	0.0001	ND	02/03/10
2037	Simazine	508.1	0.004	0.0001	NA	
2055	Trifluralin	505	---	0.001	ND	01/20/10
2625	Bentazon	515.2	---	0.001	ND	02/03/10
2626	Molinate	508.1	---	0.001	NA	
2627	Thiobencarb	508.1	---	0.001	NA	

 Volatile Organic Chemicals - method 504.1

2931	1,2-Dibromo3chloropropane	504.1	0.0002	0.00001	ND	01/24/10
2946	1,2-Dibromoethane	504.1	0.00005	0.00001	ND	01/24/10

504.1- Date Extracted: 01/23/10

505 - Date Extracted: 01/19/10

515.2- Date Extracted: 01/23/10

These test results may be used for compliance purposes as required.

- (1) Due to the limitations of EPA Method 524.2, m and p isomers of xylene are reported as an aggregate.
- (2) Total PCB's consists of the following Aroclors, each with a LRL of 0.0005 mg/L; 1016, 1221, 1232, 1242, 1248, 1254 and 1260.

David J. Vesey, Lab Director



ANALYTICAL REPORT

PAGE 1 OF 2 SAMPLE CODE: 99592

Date: 02/15/10 Report #: 99592 Laboratory ID #: FL001

Client: VALLEY CREST FARM
 ATTN: PETER LECOMPTE
 14 ALLERTON RD.
 LEBANON, NJ 08833-

Date Collected: 01/12/10
 Time Collected: 15:30
 SOURCE: VALLEY CREST FARM
 BORE HOLE 1
 LEBANON, NJ
 SOURCE WATER
 TEMP=51

Date received at lab: 01/13/10 Time received at lab: 10:30
 Collected by : E.WILSON

The results herein conform to NELAC standards, where applicable, unless otherwise narrated in the body of the report. Test results were calculated on a wet weight basis. The uncertainty of the test results are available upon request.

NOTE: "*" The MCL (Maximum Contaminant Level) or an established guideline has been exceeded for this contaminant.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL).

"NA" Not Analyzed.

Fed Id #	Analysis Performed	Method	MCL (ug/l)	LRL	Level Detected	Anal Date
1024	Cyanide	4500CN-F	200	15	ND	01/19/10
2910	T. Phenols	420.1	---	1	ND	01/14/10
1039	Perchlorate	314.0	---	0.2	NA	
2021	Carbaryl	531.1	---	1.5	ND	02/03/10
2022	Methomyl	531.1	---	1.5	ND	02/03/10
2043	Aldicarb sulfoxide	531.1	7	2.0	ND	02/03/10
2044	Aldicarb sulfone	531.1	7	1.5	ND	02/03/10
2047	Aldicarb	531.1	7	2.0	ND	02/03/10
2066	3-Hydroxycarbofuran	531.1	---	1.0	ND	02/03/10
2036	Oxamyl	531.1	200	1.5	ND	02/03/10
2046	Carbofuran	531.1	40	2.5	ND	02/03/10
2045	Metolachlor	525.2	---	0.20	ND	02/11/10
2076	Butachlor	525.2	---	0.20	ND	02/11/10
2077	Propachlor	525.2	---	0.20	ND	02/11/10
2356	Aldrin	525.2	---	0.20	ND	02/11/10
2070	Dieldrin	525.2	---	0.20	ND	02/11/10
2015	Methoxychlor	525.2	40	0.20	ND	02/11/10
2595	Metribuzin	525.2	---	0.20	ND	02/11/10
2626	Molinate	525.2	---	0.04	ND	02/11/10
2035	Di(2-ethylhexyl) adipate	525.2	400	0.20	ND	02/11/10
2274	Hexachlorobenzene	525.2	1	0.20	ND	02/11/10
2039	Di(2-ethylhexyl) phthalate	525.2	6	0.5	ND	02/11/10
2306	Benzo(A) pyrene	525.2	0.2	0.20	ND	02/11/10
2037	Simazine	525.2	4	0.20	ND	02/11/10



ANALYTICAL REPORT

Page 2 of 2 Sample Code: 99592

Fed Id #	Analysis Performed	Method	MCL (ug/l)	LRL	Level Detected	Anal Date
-2051	Alachlor	525.2	2	0.20	ND	02/11/10
-2050	Atrazine	525.2	3	0.20	ND	02/11/10
-2626	Molinate	525.2	---	0.20	ND	02/11/10
-2627	Thiobencarb	525.2	---	0.20	ND	02/11/10
2034	Glyphosate	547	700	6.00	ND	01/25/10
2033	Endothall	548.1	100	9.00	ND	01/23/10
2032	Diquat	549.2	20	1.00	ND	02/08/10

525.2	DATE EXTRACTED	01/21/10				
548.1	DATE EXTRACTED	01/15/10				
549.2	DATE EXTRACTED	01/18/10				

 These test results may be used for compliance purposes as required.

 Ronald Lyons, Lab Director



ANALYTICAL REPORT

PAGE 1 OF 1 SAMPLE CODE: 99593

Date: 01/20/10 Report #: 99593 Laboratory ID #: FL001

Client: VALLEY CREST FARM
 ATTN: PETER LECOMPTE
 14 ALLERTON RD.
 LEBANON, NJ 08833-

Date Collected: 01/12/10
 Time Collected: 15:30
 SOURCE: VALLEY CREST FARM
 BORE HOLE 1
 SOURCE WATER
 TEMP=51

Date received at lab: 01/13/10 Time received at lab: 10:30

Collected by : E.WILSON

The results herein conform to NELAC standards, where applicable, unless otherwise narrated in the body of the report. Test results were calculated on a wet weight basis. The uncertainty of the test results are available upon request.

NOTE: "*" The MCL (Maximum Contaminant Level) or an established guideline has been exceeded for this contaminant.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL).

Fed Id #	Analysis Performed	Method	MCL (mg/l)	LRL	Level Detected	Anal Date	Anal Time
1044	Ortho Phosphate	300.0	---	0.05	ND	01/13/10	20:35

These test results may be used for compliance purposes as required.

 Ronald Lyons, Lab Director



ANALYTICAL REPORT

PAGE 1 OF 1 SAMPLE CODE: 99601

Date: 02/03/10 Report #: 99601 Laboratory ID #: FL001

Client: VALLEY CREST FARM
 ATTN: PETER LECOMPTE
 14 ALLERTON RD.
 LEBANON, NJ 08833-

Date Collected: 01/12/10
 Time Collected: 15:30
 SOURCE: VALLEY CREST FARM
 BORE HOLE 1
 LEBANON, NJ
 SOURCE WATER
 TEMP=51

Date received at lab: 01/14/10 Time received at lab: 08:45
 Collected by : E.WILSON

The results herein conform to NELAC standards, where applicable, unless otherwise narrated in the body of the report. Test results were calculated on a wet weight basis. The uncertainty of the test results are available upon request.

NOTE: "*" The MCL (Maximum Contaminant Level) or an established guideline has been exceeded for this contaminant.
 "ND" This contaminant was not detected at or above our lower reporting limit (LRL).
 "NA" Not Analyzed.

Fed Id #	Analysis Performed	Method	MCL (ug/l)	LRL	Level Detected	Anal Date
2110	Silvex (2,4,5-TP)	515.3	50	1.0	ND	01/26/10
2105	2,4-D	515.3	70	1.5	ND	01/26/10
2031	Dalapon	515.3	200	12.0	ND	01/26/10
2440	Dicamba	515.3	---	0.5	ND	01/26/10
2041	Dinoseb	515.3	7	3.5	ND	01/26/10
2326	Pentachlorophenol	515.3	1	0.5	ND	01/26/10
2040	Picloram	515.3	500	1.0	ND	01/26/10
2625	Bentazon	515.3	---	1.5	ND	01/26/10

515.3 DATE EXTRACTED 01/21/10

These test results may be used for compliance purposes as required.

 Ronald Lyons, Lab Director

Report Prepared for:

Susan Henderson
National Testing Laboratories
6571 Wilson Mills Road
Cleveland OH 44143

**REPORT OF
LABORATORY
ANALYSIS FOR
2,3,7,8-TCDD**

Report Summary:

Enclosed are analytical results of one drinking water sample analyzed for 2,3,7,8-TCDD content. This sample was analyzed according to Method 1613B by High Resolution Gas Chromatography/High Resolution Mass Spectrometry.

The results reported for this sample and the associated quality control samples were all within the criteria described in Method 1613B. If you have any questions or concerns regarding these results, please contact Nate Habte, your Pace Project Manager.

Pace Project Number:

10120461


Report Prepared Date:

January 28, 2010

Product Source

Company Name: Valley Crest Farm
Company City & State: Lebanon NJ
Sample ID: 714995
Source Name: Valley Crest Farm Bore Hole 1
Source Location: Lebanon NJ
PWS ID: N/A
Date & Time Collected: 01/12/2010 @ 15:30
Collected By: EW
Laboratory Sample ID: 10120461001
Date Sampled: 01/12/2010 @ 15:30
Date Received: 01/14/2010 @ 09:40

This report has been reviewed by:



January 28, 2010


Nate Habte, Project Manager
(612) 607-6407
(612) 607-6444 (fax)
natnael.habte@pacclabs.com



Report of Laboratory Analysis

This report should not be reproduced, except in full, without the written consent of Pace Analytical Services, Inc.

The results relate only to the samples included in this report.



Minnesota Laboratory Certifications

Authority	Certificate #	Authority	Certificate #
Alabama	40770	Montana	92
Alaska	MN00064	Nebraska	
Arizona	AZ0014	Nevada	MN00064_2000
Arkansas	88-0680	New Jersey (N	MN002
California	01155CA	New Mexico	MN00064
Colorado	MN00064	New York (NEL	11647
Connecticut	PH-0256	North Carolina	27700
EPA Region 5	WD-15J	North Dakota	R-036
EPA Region 8	8TMS-Q	Ohio	4150
Florida (NELAP	E87605	Ohio VAP	CL101
Georgia (DNR)	959	Oklahoma	D9922
Guam	09-019r	Oregon (ELAP)	MN200001-005
Hawaii	SLD	Oregon (OREL	MN200001-005
Idaho	MN00064	Pennsylvania	68-00563
Illinois	200012	Saipan	MP0003
Indiana		South Carolina	74003001
Indiana	C-MN-01	Tennessee	2818
Iowa	368	Tennessee	02818
Kansas	E-10167	Texas	T104704192-08
Kentucky	90062	Utah (NELAP)	PAM
Louisiana	LA0900016	Virginia	00251
Maine	2007029	Washington	C755
Maryland	322	West Virginia	9952C
Michigan	9909	Wisconsin	999407970
Minnesota	027-053-137	Wyoming	8TMS-Q
Mississippi	MN00064		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, Inc.

Reporting Flags

- A = Reporting Limit based on signal to noise
- B = Less than 10x higher than method blank level
- C = Result obtained from confirmation analysis
- D = Result obtained from analysis of diluted sample
- E = Exceeds calibration range
- I = Interference present
- J = Estimated value
- Nn = Value obtained from additional analysis
- P = PCDE Interference
- R = Recovery outside target range
- S = Peak saturated
- U = Analyte not detected
- V = Result verified by confirmation analysis
- X = %D Exceeds limits
- Y = Calculated using average of daily RFs
- * = See Discussion

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc.



NATIONAL TESTING LABORATORY
BROWARD TESTING LABORATORY
 PHONE: (800) 458-3330 FAX: (440) 449-8585

PLEASE COMPLETE THIS FORM AND RETURN IT WITH YOUR WATER SAMPLE.
 THE INFORMATION AS PROVIDED HEREIN WILL BE USED TO REPORT YOUR
 ANALYTICAL RESULTS. THE BLOCK TO THE RIGHT IS RESERVED FOR OUR
 LABORATORY USE ONLY.

CUSTOMER INFORMATION:

VALLEY CREST FARM
 ATTN: PETER LECOMPTE
 14 ALLERTON RD.
 LEBANON NJ 08833

PWS ID# (if applicable) _____

CONTACT NAME _____

TELEPHONE NO. _____

FAX NO. _____

SOURCE WATER INFORMATION:

SOURCE NAME Valley Crest Farm Bore hole 1

CITY Lebanon
 (if different than above)

STATE NJ
 (if different than above)

SAMPLE COLLECTED BY Erik Wilson
 (Signature)

SAMPLE COLLECTED BY Erik Wilson
 (Please Print)

DATE Collected: 1/12/10 TIME Collected (in military time, ie 15:00=3:00pm): 15:30
 Check Time Zone: EST CST MST PST

SAMPLE TEMPERATURE 51 FIELD pH _____

MEASURED AT SOURCE BY Erik Wilson
 (Please Print)

FORM COMPLETED BY Erik Wilson
 (Please Print)

ADDITIONAL COMMENTS

* AsL #34774W
 Bromide poured 1/13/10 by SR

10120461001
 714995
 SAMPLE NUMBER
 LAB ACCOUNTING INFORMATION:
 PAYMENT \$ _____
 CHECK # _____
 LAB SPECIAL INSTRUCTIONS:
 1139864 - 0888
 TC&SPC
 TC & SPC 50 WO DOBP
 R:9008 2:909 TSR:MRN/V
 LAB COMMENTS:
 BOREHOLE SOURCE #1 - NY
 COMPLIANCE
 515.3 (9616) to BTL
 A/B, 226,228, U TO PACE/PA
 DIOXIN TO PACE/MN
 ASBESTOS TO STL EMSL
 *RADON TO A+L
 PERCHLORATE TO EHL
 4°C
 LAB SAMPLE INFORMATION:
 DATE RCVD.: 1/13/10 TIME (military): 0935
 BY: SR
 (Signature)
 Sample receipt criteria checked & acceptable.
 Deviations from acceptable sample receipt
 criteria noted on PSA form.
 COMPLIANCE APPROVAL ONLY
 1 vial for 504.1
 received unused SR/NPL
 1/13/10